


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.03V I:0.1284A P:15.189W PF:0.9859 Freq:60.00Hz Lamp Flux:1134.63x1 lm		
NAME: R2ARDT-W827-WT	TYPE: Recessed-mounted Luminaire	HEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: WAC Lighting	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 74.70 lm/W			
MODEL		Imax(cd)	1386	S/MH(C0/180)	0.76
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	0.76
RATED VOLTAGE(V)	120	TOTAL FLUX(lm)	1134.6	η UP,DN(C0-180)	0.0,50.2
NOMINAL FLUX(lm)	1134.63	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.1,49.7
LAMPS INSIDE	1	η up(%)	0.1	CIBSE SHR NOM	0.75
TEST VOLTAGE(V)	120	η down(%)	99.9	CIBSE SHR MAX	0.85

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.464m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM


ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	$\%lum, lamp$
10	1219	1234	1232	1226	1220	1206	1211	1219	0- 10	124.3	124.3	11,11
20	872.3	887.2	885.3	876.8	869.3	858.9	861.3	870.7	10- 20	291.2	415.6	36.6,36.6
30	482.6	498.3	505.2	499.6	499.2	484.7	485.3	488.9	20- 30	312.0	727.6	64.1,64.1
40	178.5	186.3	198.4	197.2	199.0	191.2	187.4	187.8	30- 40	204.8	932.4	82.2,82.2
50	75.67	75.93	77.58	77.67	78.73	77.95	77.81	77.68	40- 50	90.84	1023	90.2,90.2
60	44.23	44.08	44.34	45.11	46.57	45.72	45.11	44.78	50- 60	53.10	1076	94.9,94.9
70	24.61	25.09	25.63	26.11	26.70	26.19	25.72	25.14	60- 70	34.11	1110	97.9,97.9
80	9.501	9.843	10.23	10.51	10.88	10.34	9.933	9.820	70- 80	18.34	1129	99.5,99.5
90	0.0019	0.0122	0.0221	0.0390	0.1226	0	0	0	80- 90	4.958	1134	99.9,99.9
100	0	0	0	0	0	0	0	0	90-100	0.0011	1134	99.9,99.9
110	0	0	0	0	0	0	0	0	100-110	0	1134	99.9,99.9
120	0.0163	0.0162	0.0140	0.0147	0.0282	0.0299	0.0322	0.0322	110-120	0.0058	1134	99.9,99.9
130	0.0887	0.0876	0.0845	0.0845	0.1487	0.1530	0.1581	0.1554	120-130	0.0569	1134	99.9,99.9
140	0.1907	0.1861	0.1846	0.1842	0.3521	0.3571	0.3630	0.3589	130-140	0.1482	1134	99.9,99.9
150	0.3382	0.3339	0.3278	0.3279	0.5658	0.5710	0.5758	0.5748	140-150	0.2265	1134	100,100
160	0.4541	0.4467	0.4382	0.4407	0.7248	0.7249	0.7297	0.7288	150-160	0.2401	1134	100,100
170	0.5380	0.5299	0.5297	0.5256	0.7597	0.7590	0.7596	0.7610	160-170	0.1757	1135	100,100
180	0.7139	0.7104	0.7021	0.7035	0.7074	0.7039	0.7010	0.6981	170-180	0.0633	1135	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.2DEG
 Operators:Oliver
 Test Date:2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:2.464m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.464m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

pcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.09	1.07	1.04	1.07	1.05	1.02	1.03	1.01	.99	.99	.98	.96	.96	.95	.93	.92
2.0	1.01	.96	.92	.99	.95	.91	.96	.92	.89	.93	.90	.87	.90	.87	.85	.84
3.0	.93	.87	.83	.92	.86	.82	.89	.85	.81	.86	.83	.80	.84	.81	.78	.77
4.0	.86	.80	.75	.85	.79	.75	.83	.78	.74	.81	.77	.73	.79	.75	.72	.71
5.0	.80	.74	.69	.79	.73	.69	.77	.72	.68	.76	.71	.68	.74	.70	.67	.65
6.0	.75	.69	.64	.74	.68	.64	.73	.67	.63	.71	.66	.63	.70	.66	.62	.61
7.0	.70	.64	.59	.70	.64	.59	.68	.63	.59	.67	.62	.59	.66	.62	.58	.57
8.0	.66	.60	.55	.66	.60	.55	.64	.59	.55	.63	.58	.55	.62	.58	.55	.53
9.0	.62	.56	.52	.62	.56	.52	.61	.55	.52	.60	.55	.51	.59	.55	.51	.50
10.0	.59	.53	.49	.59	.53	.49	.58	.52	.49	.57	.52	.48	.56	.52	.48	.47



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:

WEC AND CCEC

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.204	.116	.037	.197	.112	.036	.184	.106	.034	.172	.099	.032	.161	.094	.030		
2.0	.194	.106	.033	.188	.103	.032	.177	.098	.031	.167	.094	.029	.158	.089	.028		
3.0	.183	.097	.029	.178	.095	.029	.168	.091	.028	.160	.088	.027	.152	.084	.026		
4.0	.172	.089	.026	.168	.088	.026	.160	.085	.025	.152	.082	.025	.145	.079	.024		
5.0	.162	.083	.024	.159	.081	.024	.152	.079	.023	.145	.077	.023	.139	.074	.022		
6.0	.154	.077	.022	.150	.076	.022	.144	.074	.021	.138	.072	.021	.133	.070	.021		
7.0	.146	.072	.020	.143	.071	.020	.137	.069	.020	.132	.068	.020	.127	.066	.019		
8.0	.138	.068	.019	.136	.067	.019	.131	.065	.019	.126	.064	.018	.122	.063	.018		
9.0	.132	.064	.018	.129	.063	.018	.125	.062	.018	.121	.061	.017	.117	.059	.017		
10.0	.126	.060	.017	.124	.060	.017	.120	.059	.017	.116	.058	.016	.112	.056	.016		

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.191	.191	.191	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.174	.158	.143	.149	.135	.123	.102	.093	.085	.058	.054	.050	.019	.017	.016	
2.0	.160	.133	.111	.137	.114	.096	.094	.079	.067	.054	.046	.039	.017	.015	.013	
3.0	.148	.114	.087	.127	.099	.076	.087	.069	.053	.050	.040	.031	.016	.013	.010	
4.0	.138	.100	.070	.119	.086	.061	.082	.060	.043	.047	.035	.025	.015	.011	.008	
5.0	.130	.089	.058	.112	.077	.050	.077	.054	.036	.045	.031	.021	.014	.010	.007	
6.0	.123	.079	.048	.105	.069	.042	.073	.048	.030	.042	.028	.018	.014	.009	.006	
7.0	.116	.072	.041	.100	.062	.036	.069	.044	.025	.040	.026	.015	.013	.008	.005	
8.0	.110	.066	.035	.095	.057	.031	.066	.040	.022	.038	.024	.013	.012	.008	.004	
9.0	.105	.061	.031	.090	.053	.027	.063	.037	.019	.036	.022	.011	.012	.007	.004	
10.0	.100	.056	.027	.086	.049	.024	.060	.034	.017	.035	.020	.010	.011	.007	.003	

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	10.0	11.0	10.2	11.2	11.4	10.1	11.2	10.4	11.3	11.5
3H	10.6	11.5	10.8	11.7	11.9	10.7	11.7	11.0	11.9	12.1
4H	10.8	11.7	11.1	12.0	12.2	11.0	11.9	11.3	12.1	12.4
6H	11.0	11.9	11.3	12.1	12.4	11.2	12.0	11.5	12.3	12.6
8H	11.0	11.9	11.4	12.1	12.4	11.2	12.1	11.6	12.3	12.6
12H	11.1	11.9	11.4	12.1	12.4	11.3	12.1	11.6	12.3	12.6
4H 2H	10.1	11.1	10.4	11.3	11.5	10.3	11.2	10.6	11.4	11.7
3H	10.9	11.7	11.3	12.0	12.3	11.1	11.9	11.4	12.2	12.4
4H	11.3	12.0	11.7	12.3	12.6	11.5	12.2	11.8	12.5	12.8
6H	11.6	12.2	12.0	12.6	12.9	11.8	12.4	12.1	12.7	13.1
8H	11.7	12.3	12.1	12.6	13.0	11.9	12.5	12.3	12.8	13.2
12H	11.7	12.3	12.1	12.6	13.0	11.9	12.5	12.3	12.8	13.2
8H 4H	11.4	12.0	11.8	12.4	12.7	11.6	12.2	12.0	12.5	12.9
6H	11.8	12.3	12.2	12.7	13.1	12.0	12.4	12.4	12.8	13.3
8H	11.9	12.4	12.4	12.8	13.2	12.1	12.6	12.6	13.0	13.4
12H	12.0	12.4	12.5	12.8	13.3	12.2	12.6	12.7	13.1	13.5
12H 4H	11.4	11.9	11.8	12.3	12.7	11.5	12.1	12.0	12.5	12.9
6H	11.8	12.2	12.3	12.7	13.1	12.0	12.4	12.4	12.8	13.3
8H	12.0	12.3	12.4	12.8	13.3	12.2	12.5	12.6	13.0	13.4
Variations with the observer position at spacings:										
S = 1.0H	+ 0.8 / - 0.9					+ 1.0 / - 1.0				
1.5H	+ 1.6 / - 0.7					+ 1.9 / - 0.8				
2.0H	+ 0.9 / - 0.6					+ 1.1 / - 0.6				

CIE Pub.117, 1135 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 0.4$)

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:


UTILIZATION FACTORS TABLE

REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	80	73	68	80	73	68	79	72	68	64
0.80	89	81	77	88	81	77	87	80	76	72
1.00	94	87	83	93	87	82	91	87	82	77
1.25	99	92	88	98	92	88	95	91	87	82
1.50	102	96	92	101	95	91	98	94	90	85
2.00	106	100	97	104	99	96	101	97	94	88
2.50	108	103	99	106	102	99	103	99	97	90
3.00	110	106	102	108	104	101	104	101	99	92
4.00	112	109	106	110	107	105	106	104	102	94
5.00	114	111	108	111	109	107	107	105	104	96
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004				Suspended				SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:


ISOCANDELA DIAGRAM



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.464m [K=1.0000]
Remarks:

AAI CURVES




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:120.03V I:0.1284A P:15.189W PF:0.9859 Freq:60.00Hz Lamp Flux:1134.63x1 lm		
NAME: R2ARDT-W827-WT	TYPE: Recessed-mounted Luminaire	HEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: WAC Lighting	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	815
L_0~180(75)av	664
L_0~180(85)av	505
L_90~270(65)av	800
L_90~270(75)av	660
L_90~270(85)av	497
L_45(65)av	807
L_45(75)av	661
L_45(85)av	500

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.2DEG
Operators: Oliver
Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
Humidity: 65.0%
Test Distance: 2.464m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--1

UNIT: cd

C(DEG) γ (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385	1385			
5	1343	1346	1350	1351	1350	1347	1344	1339	1342	1337	1335	1335	1338	1340	1343	1346			
10	1219	1229	1234	1235	1232	1231	1226	1218	1220	1210	1206	1208	1211	1213	1219	1225			
15	1041	1050	1059	1061	1059	1057	1051	1043	1041	1033	1031	1031	1034	1038	1044	1048			
20	872	880	887	889	885	885	877	868	869	863	859	859	861	866	871	875			
25	676	685	698	701	699	703	695	686	691	683	676	677	678	680	683	686			
30	483	488	498	503	505	506	500	493	499	492	485	486	485	485	489	491			
35	314	320	326	335	337	338	336	333	337	329	325	323	323	323	322	324			
40	179	183	186	193	198	200	197	195	199	193	191	189	187	188	188	187			
45	106	107	109	112	115	116	115	113	114	112	111	111	110	110	111	110			
50	75.7	75.7	75.9	76.6	77.6	77.9	77.7	77.3	78.7	78.3	77.9	77.7	77.8	77.7	77.7	77.8			
55	57.8	57.9	57.8	57.9	58.3	58.5	58.8	58.8	60.1	59.8	59.5	59.1	58.9	58.6	58.7	58.8			
60	44.2	44.4	44.1	44.0	44.3	44.6	45.1	45.6	46.6	46.3	45.7	45.4	45.1	44.7	44.8	44.9			
65	33.3	33.5	33.4	33.4	33.5	33.9	34.5	34.8	35.6	35.3	34.8	34.4	34.1	33.8	33.8	33.8			
70	24.6	24.8	25.1	25.4	25.6	25.9	26.1	26.1	26.7	26.5	26.2	25.9	25.7	25.2	25.1	25.1			
75	16.2	16.4	16.6	16.9	17.1	17.4	17.5	17.5	18.2	17.9	17.5	17.3	17.0	16.9	16.8	16.8			
80	9.50	9.64	9.84	10.1	10.2	10.3	10.5	10.5	10.9	10.6	10.3	10.1	9.93	9.84	9.82	9.84			
85	3.85	4.02	4.20	4.37	4.52	4.64	4.69	4.66	4.94	4.73	4.50	4.29	4.14	4.07	4.06	4.13			
90	0.00	0.01	0.01	0.02	0.02	0.04	0.04	0.02	0.12	0.04	0.00	0.00	0.00	0.00	0.00	0.00			
95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
105	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.01			
120	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.01	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03			
125	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08			
130	0.09	0.09	0.09	0.08	0.08	0.08	0.08	0.08	0.15	0.15	0.15	0.16	0.16	0.16	0.16	0.15			
135	0.14	0.14	0.13	0.13	0.13	0.13	0.13	0.13	0.25	0.25	0.25	0.26	0.26	0.26	0.26	0.25			
140	0.19	0.19	0.19	0.18	0.18	0.18	0.18	0.19	0.35	0.35	0.36	0.36	0.36	0.36	0.36	0.36			
145	0.27	0.27	0.26	0.26	0.26	0.26	0.26	0.26	0.46	0.47	0.47	0.47	0.47	0.47	0.47	0.47			
150	0.34	0.34	0.33	0.33	0.33	0.33	0.33	0.33	0.57	0.57	0.57	0.58	0.58	0.58	0.57	0.57			
155	0.40	0.39	0.39	0.39	0.38	0.39	0.38	0.39	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66			
160	0.45	0.45	0.45	0.44	0.44	0.44	0.44	0.44	0.72	0.73	0.72	0.73	0.73	0.73	0.73	0.72			
165	0.50	0.50	0.49	0.49	0.49	0.49	0.49	0.48	0.76	0.76	0.76	0.76	0.76	0.76	0.76	0.76			
170	0.54	0.54	0.53	0.53	0.53	0.52	0.53	0.52	0.76	0.76	0.76	0.76	0.76	0.76	0.76	0.76			
175	0.63	0.63	0.62	0.62	0.62	0.62	0.62	0.62	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74			
180	0.71	0.71	0.71	0.71	0.70	0.70	0.70	0.71	0.71	0.71	0.70	0.70	0.70	0.70	0.70	0.70			

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.2DEG
 Operators: Oliver
 Test Date: 2018-04-02

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.366
 Humidity: 65.0%
 Test Distance: 2.464m [K=1.0000]
 Remarks: